

Mandatory Language for a Maximum Contaminant Level Violation
MCL, AVERAGE / SELENIUM

The Texas Commission on Environmental Quality (TCEQ) has notified the Town North Village public water system TX1520094 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for selenium. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for selenium to be 0.05 milligrams per liter (mg/L) based on the running annual average (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for selenium indicates a compliance value in **quarter four 2025** of **0.06** mg/L for EP001.

Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in the fingers or toes, or problems with their circulation.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

South Plains Water Supply Corporation has applied for funding from the Texas Water Supply Corporation for the construction of a new water treatment plant.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact David Salinas at (806) 893-9979.

Posted /Delivered on: April 1, 2026